



“कला संस्कृतियुक्त, स्वच्छ समुन्नत टोखा नगर”

टोखा नगरपालिका

द्वारा नगरपालिका

नगर कार्यपालिकाको कार्यालय

पत्र संख्या: ०८२/८३ (योजना तथा अनुगमन शाखा)

च.नं.: २०३



मैजुहिटी, काठमाडौं
बागमती प्रदेश, नेपाल।

मिति: २०८२/०६/०९

ने.सं.: ११४५ कौलाय्व ४ विहीवार

श्री सम्बन्धित व्यावसायीहरु

बिषय — दररेट पेश गर्ने सम्बन्धमा ।


वडा नं. १० र ११ स्थित विद्युत पोलहरुमा सडक बत्ती जडान कार्यको लागि विनियोजित बजेटको कार्यक्रम कार्यान्वयनको लागि तयार भएको संलग्न BOQ अनुसारको सामग्रीहरुको दररेट उल्लेख गरी तपशिलको मिति, समय र स्थानमा तपशिलका कागजातहरु सहित प्रस्ताव पेश गर्नु हुन अनुरोध छ ।

प्रस्ताव साथ संलग्न गर्नु पर्ने कागजातहरु:

१. सम्बन्धित फर्म/ कम्पनिको निवेदन
२. कम्पनि / फर्म दर्ता नविकरण प्रमाणपत्रको प्रतिलिपी
३. भ्याट दर्ता प्रमाणपत्र
४. आ.व.२०८०/८१ को करचुक्ता प्रमाणपत्र
५. कार्यालयबाट जारी संलग्न BOQ मा फर्मको छाप र आधिकारीक व्यक्तिको दस्तखत हुनुपर्ने ।
६. संलग्न Technical Specifications fully comply गरी सहिछाप गरेको हुनु पर्ने ।
७. कम्तिमा २ वर्ष वारेन्टी समय भएको पत्र संलग्न हुनुपर्नेछ ।

खामबन्दी प्रस्ताव पेश गर्नु पर्ने अन्तिम मिति,समय र स्थान		प्रस्ताव खोलिने मिति, समय र स्थान	
मिति	२०८२/६/१२ गते	मिति	२०८२/६/१२
समय	मध्यान्ह १२:०० वजे भित्र	समय	दिनको १:०० वजे
स्थान	टोखा नगरपालिका कार्यालय, मैजुहिटी, काठमाडौं	स्थान	टोखा नगरपालिका कार्यालय, मैजुहिटी, काठमाडौं

पूनश्च: छनौट भई सम्झौता गर्न नआएमा कालो सूचिमा राखिने प्रकृया अगाडि बढाइनेछ । अन्य कुरा सावर्जनिक खरिद ऐन तथा नियमावली बमोजिम हुनेछ ।


(अनिल प्रसाद जोशी)
वरिष्ठ शाखा अधिकृत





Municipal Executive Office
Maijuhiti, Kathmandu
Province No. 3, Nepal
Bill Of Quantities

Law

Sign
Signature

कार्यालय वा परियोजनाको नाम:- टोखा नगरपालिका ;(पुर्वाधार विकास) वडा नं १० र ११
कार्यक्रम / योजनाको नाम र कार्यान्वयन हुने स्थल:-सडक बत्ती व्यवस्थापन तथा सडक बत्ती जडान

बजेट उप शीर्षक नः ११३७ र १२२४

S.N.	Description of items	Quantity	Unit	Unit Rate		Amount	Remarks
				In figure	In words		
	A. Provisional work						
1.00	Provide and installation of project information Board as specified as per instruction.	2.00	Ps				
	B. Construction works						
1.00	Supplying, installing, testing (including Lab test) and commissioning of 40-60 watt LED AC street light having manufacture warrented from authorized dealer/manufacturer of 2 years as per specification and instruction of Engineer including all necessary accessories, sensors etc, all complete work.	102.00	Set				64 sets in ward 10 and 38 sets in ward 11
2.00	Supply and Fitting of MS light Arm with necessary wires, fitting charge all complete.	102.00	Set				64 sets in ward 10 and 38 sets in ward 11
	Sub-total without VAT and P.S.						
	VAT @13%						
	Total with VAT and P.S.						

Name of Form

Proprietor's Name :

Address of Proprietors:

Technical Specifications

- 1 Street Light**
- S. No. Requirements**
- 1 Manufacturer Name:
 - 2 Brand/Model:
 - 3 Type : SMD
 - 4 Power : (40-60) watt LED Lamp
 - 5 LED Efficacy : at least 130 Lumen/Watt
 - 6 Input Range: 90-275VAC
 - 7 LED Beam angle: equal or greater than 2*50 degree
 - 8 Color Temperature : 3500-4500 K as per ANSI C78.377A CCT standard.
 - 9 Minimum Features: Auto shut down, auto restart, Open and short circuit protection, overvoltage protection.
 - 10 CRI : ≥ 70
 - 11 Driver efficiency: Must have Driver Circuit cum Charge Controller with not less than 88% efficiency.
 - 12 Surface Temperature: Must remain below 50 degree celsius.
 - 13 Working Life: at least 50,000 hours
 - 14 Certification : RETS or eqv Certified.(Lab test must be carried out by the contractor before installation as per site Engineer.)
 - 15 IP Rating :Must Submit IP ≥ 66 or above Compliance Certificate.
 - 16 THD: <10%
 - 18 Power Factor: ≥ 0.91
 - 19 Warranty Period: Minimum period of 2 years.
 - 20 SPD:10 kv
- A. Technical Datasheet, Brochure, IS Certificates, Manufacture's warranted letter from Authorized dealers/manufacture, Technical Specification Detail are essential. Product should have Photosensor compulsory. Need to turn on at night time and turn off at day time automatically.
- B. In case of problems occurred within warranty period must be solved within 24 hours.
- C. Must incorporate all necessary accessories in case of missing BOQ in order to complete whole installation package.
- D. Light power supply should be given from NEA (Nepal Electricity Authority) grid.
- E. Light height and alignment should be according to NEA rules & regulations.
- F. Hot dip galvanized light arms must be provided for fix AC Light for proper alignment.

[Signature]
अनिल कार्की
सब-इंजिनियर

[Signature]
(इ. इन्जिनियर)

[Signature]
205212139

[Signature]
2052102139